

MARYLAND ARMY NATIONAL GUARD (MDARNG) DRINKING WATER PFAS SNAPSHOT

The Army National Guard is committed to ensuring quality drinking water is provided to its Soldiers, and civilians. Proactive sampling is performed by the Army National Guard on its drinking water systems, as well as, coordination with other purveyors to ensure perfluorooctane sulfonate (PFOS) and perfluorooctanoic acid (PFOA) remains below the Environmental Protection Agency (EPA) lifetime health advisory (HA) level of 70 parts per trillion (ppt). The EPA HA is not an enforceable or a regulatory standard, and represents a concentration in drinking water that is not expected to produce adverse health effects if the water is consumed over a lifetime.

Drinking Water Status: Finished drinking water, which is the treated water people drink at Havre de Grace Military Reservation, does not contain PFOS/PFOA above the EPA HA. Additionally, Army National Guard-provided drinking water complies with the standards of the Safe Drinking Water Act (SDWA), a federal law designed to protect the quality of drinking water supplied to the American public. The Army National Guard will continue to monitor on-base drinking water to ensure the EPA HA or a properly promulgated state drinking water standard is not exceeded.

Test Date: 10-Aug 2023

PFOA + PFOS Results: 1.5 ng/L + 1.3 ng/L

Future Testing Event: August 2026

Type of Drinking Water System: Non-DoD Owned Water Purveyor

For Questions Contact: Maryland National Guard State Public Affairs Office

Office Phone Number: 667-296-3662

Office E-mail Address: ng.md.mdarng.list.pao@army.mil

Water quality report: A consumer confidence report is available for this location.