

NEW YORK ARMY NATIONAL GUARD (NYARNG) DRINKING WATER PFAS SNAPSHOT

The Army National Guard is committed to ensuring quality drinking water is provided to its Soldiers, and civilians. Proactive sampling is performed by the Army National Guard on its drinking water systems, as well as coordination with other purveyors to ensure perfluorooctane sulfonate (PFOS) and perfluorooctanoic acid (PFOA) remains below the New York State Department Health (NYSDOH) Maximum Contaminant Level (MCL) of 10 parts per trillion (ppt). The NYSDOH MCL is an enforceable regulatory standard and represents a concentration in drinking water that is expected to produce adverse health effects if the water is consumed over a lifetime.

Drinking Water Status: Finished drinking water, which is the treated water people drink at Horseheads Training Site, does not contain PFOS/PFOA above the EPA Health Advisory (HA). Additionally, Army National Guard-provided drinking water complies with the standards of the Safe Drinking Water Act (SDWA), a federal law designed to protect the quality of drinking water supplied to the American public. The Army National Guard will continue to monitor on-base drinking water to ensure the EPA HA or a properly promulgated state drinking water standard is not exceeded.

Test Date: APRIL 05, 2023

PFOA + PFOS Results: 0.265 ppt

Future Testing Event: APRIL 05, 2025

Type of Drinking Water System: Army National Guard-owned

For Questions Contact: National Guard State Environmental Office

Office Phone Number: 518-786-4367

Office E-mail Address: steves.vanderpool.mil@army.mil

Water quality report: A water quality report is not required for this location.